

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1607A26**
NRC Sample ID: **1607A26-01A**
Collection Date: **7/13/2016 7:00:00 AM**
Received Date: **7/22/2016 11:36:00 AM**
Reported Date: **8/2/2016 2:19:41 PM**

Sample Information:

X023086 Wallowa ESD

Client Sample ID: Hallway DF
Collectors Name: Christian Zollman
Sample Location: Hallway DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00903		0.0001	mg/L	0.020 AL	7/29/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1607A26**
NRC Sample ID: **1607A26-02A**
Collection Date: **7/13/2016 7:00:00 AM**
Received Date: **7/22/2016 11:36:00 AM**
Reported Date: **8/2/2016 2:19:41 PM**

Sample Information:

X023086 Wallowa ESD

Client Sample ID: 105 Breakroom
Collectors Name: Christian Zollman
Sample Location: 105 Breakroom
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00148		0.0001	mg/L	0.020 AL	7/29/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit